

Addendum # 2

Informal Solicitation # 5438 for

RainWise Green Stormwater Infrastructure Consultant Services For Assessment and Installation at 513-517 S. Cloverdale

Date of Addendum # 2: April 21, 2021

The Informal Solicitation for the above-named project is amended as noted in this Addendum. This Addendum consists of one page.

Additional information relating to SHA's response to question number 2 below just came in and is being added below and high-lighted in yellow.

Question 1. Is the building currently occupied and if so, will SHA provide outreach about the project before construction begins?

Response: *SHA has begun the outreach process with tenants. Outreach will be continuous as we try to educate tenants on why the installation is occurring at their property. SHA will also notify tenants of construction dates.*

Question 2. Does the building have limitations in the way we fasten a cistern for safety considerations?

Response: *No limitations are known for attaching or fastening cisterns to the building. If the contractor decides to attach cisterns to the building wall, they should provide details on waterproofing any penetration they would be making into the building.*

However, it is not a good idea to put holes through the siding unless absolutely necessary, that is how water leaks in and damages the wall and with the cistern against the wall it will overflow onto the wall. That said, some suggestions are:

- 1. Dig a hole to set the cistern in, it only has to be a foot or so deep, so it does not tip over.*
- 2. Install posts and attach the cistern to those. These need to be solidly in the ground or concrete.*
- 3. SHA has seen the cistern installed on its side up on a cradle, which allows water to flow from it more easily when watering.*
- 4. If you must anchor it to the wall, you will need to contact SHA's Project Manager first.*

Question 3. Shall our proposal assume Washington State L&I filing fees for prevailing wages?

Response: *Yes. You will have to work with L&I on the construction portion of this project.*

As a reminder, the Due Date for proposals is 2:00 pm on Tuesday, May 4, 2021.

END OF INFORMAL SOLICITATION ADDENDUM # 2