

## INFORMAL SOLICITATION

### BALLARD HOUSE ASBESTOS ABATEMENT Solicitation No. 5757

ADDENDUM NO. 1  
Issue Date: March 27, 2023

This Addendum containing the following revisions, additions, deletions and/or clarifications, is hereby made a part of this solicitation and Contract Documents for the above-named project. Bidders/Proposers shall take this Addendum into consideration when preparing and submitting their response to this solicitation.

This Addendum lists questions received and SHA's responses (see Item 1 below).

**Item 1.** The following is a list of questions received and SHA's responses to those questions.

Question 1. Does the mastic need to be removed or just encapsulated?

Response: *Mastic will need to be removed.*

Question 2. Is the place occupied? If so, it will need to be done in stages to allow access to the units and the end of every day?

Response: *Yes, the place is occupied. Yes, Tenants will need access to their residence at the end of each day.*

END OF ADDENDUM NO. 1