

INFORMAL SOLICITATION

Water Fixture Replacement for Conservation Solicitation No. 4954

ADDENDUM NO. 1
Issue Date March 27, 2018

This Addendum containing the following revisions, additions, deletions and/or clarifications, is hereby made a part of this solicitation and Contract Documents for the above-named project. Bidders/Proposers shall take this Addendum into consideration when preparing and submitting their response to this solicitation.

This Addendum lists questions received and SHA's responses (see Item 1 below).

Item 1. The following is a list of questions received and SHA's responses to those questions.

Question 1. Are the toilets the elongated or standard bowl?

Response: *The toilets are elongated bowl for this project.*

Question 2. Is the height standard or chair height?

Response: *The bowl height is 17".*

Question 3. Can you please tell me how many ADA units are at each location?

Response: *There is one (1) ADA unit at Fremont and seven (7) ADA units at Lake City House.*

Question 4. Is this contract a performance contract?

Response: *No.*

END OF ADDENDUM NO. 1